

TRI-DIM

Filter Corporation
PREPARED FOR:

Filter Survey Record

Date: March 2014

Everett School District

Madison Elementary
616 Pecks Dr.
Everett, WA 98203

FILTER REPRESENTATIVE:

Kerry Justin

Phone 206-453-4100 Fax 206-299-9830

ITEM #	SYSTEM IDENTIFICATION	QTY	FILTER SIZE	FILTER DESCRIPTION	PRICE EA.	QTY TO ORDER
1	Bldg 100 Classroom Wall Univents	14	13-3/8x77-1/2x1	Tri-Pleat ES40LE 23013C77D140	\$14.97	
2	Bldg 200 Annex Classroom Ceiling Univents	13	15x77-1/2x1	Tri-Pleat ES40LE 2301577D140	\$14.97	
3	Bldg 100 North Stage - AHU-1	2	16x25x2	Tri-Pleat ES40LE 2301625240	\$2.31	
4	Bldg 100 South Stage - AHU-2	2	16x25x2	Tri-Pleat ES40LE 2301625240	\$2.31	
5	Bldg 100 Secretary Office Ceiling - AHU-3	2	16x25x2	Tri-Pleat ES40LE 2301625240	\$2.31	
6	Bldg 100 Library Office Ceiling - AHU-4	4	16x25x2	Tri-Pleat ES40LE 2301625240	\$2.31	
7	Bldg 100 Computer Room Ceiling - AHU-5	1	16x25x2	Tri-Pleat ES40LE 2301625240	\$2.31	
8	Bldg 100 South Wing - HVU-1	2	16x20x2	Tri-Pleat ES40LE 2301620240	\$2.07	
9	Bldg 100 South Wing - HVU-1	2	16x25x2	Tri-Pleat ES40LE 2301625240	\$2.31	
10	Bldg 100 Center - HVU-2	2	16x20x2	Tri-Pleat ES40LE 2301620240	\$2.07	
11	Bldg 100 Center - HVU-2	2	16x25x2	Tri-Pleat ES40LE 2301625240	\$2.31	
12	Bldg 100 North End - HVU-3	1	20x25x2	Tri-Pleat ES40LE 2302025240	\$2.55	
13	Bldg 100 North End - HVU-3	1	24x24x2	Tri-Pleat ES40LE 2302424240	\$2.92	
14	Bldg 100 Gym Roof - HVU-4	4	20x25x2	Tri-Pleat ES40LE 2302025240	\$2.55	
15	Bldg 100 Gym Roof - HVU-4	2	15x25x2	Tri-Pleat ES40LE 2301525240	\$3.96	
16	200 Annex Ceiling South End - HVU-5	2	20x25x2	Tri-Pleat ES40LE 2302025240	\$2.55	
						Order total
				Total Survey	\$475.81	