

TRI-DIM

Filter Corporation
PREPARED FOR:

Filter Survey Record

Updated

Date: February 2014

Everett School District

Penny Creek Elementary
4117 132nd St. SE
Everett, WA 98028

FILTER REPRESENTATIVE:

Kerry Justin

Phone 206-453-4100 Fax 206-299-9830

ITEM NUMBER	SYSTEM IDENTIFICATION	QTY	FILTER SIZE	FILTER DESCRIPTION	PRICE EA.	QTY TO ORDER
1	Bldg A Attic Mechanical Area Fan Coil AHU's	2	20x20x2	Tri-Pleat ES40LE 2302020240	\$2.31	
2	Bldg A Attic Mechanical Area Fan Coil AHU's	7	20x25x2	Tri-Pleat ES40LE 2302025240	\$2.55	
3	Bldg B Attic Mechanical Area Fan Coil AHU's	2	20x20x2	Tri-Pleat ES40LE 2302020240	\$2.31	
4	Bldg B Attic Mechanical Area Fan Coil AHU's	8	20x25x2	Tri-Pleat ES40LE 2302025240	\$2.55	
5	Bldg C Attic Mechanical Area Fan Coil AHU's	2	20x20x2	Tri-Pleat ES40LE 2302020240	\$2.31	
6	Bldg C Attic Mechanical Area Fan Coil AHU's	8	20x25x2	Tri-Pleat ES40LE 2302025240	\$2.55	
7	Bldg C Attic Mechanical Area New Addition AHU's	7	24x24x2	Tri-Pleat ES40LE 2302424240	\$2.92	
8	Bldg D Attic Mechanical Area Fan Coil AHU's	6	20x25x2	Tri-Pleat ES40LE 2302025240	\$2.55	
9	Bldg D Attic Mechanical Area Fan Coil AHU's	2	24x24x2	Tri-Pleat ES40LE 2302424240	\$2.92	
10	Bldg E Attic Mechanical Area Fan Coil AHU's	3	16x20x2	Tri-Pleat ES40LE 2301620240	\$2.07	
11	Bldg E Attic Mechanical Area Fan Coil AHU's	10	20x20x2	Tri-Pleat ES40LE 2302020240	\$2.31	
12	Bldg E Attic Mechanical Area Fan Coil AHU's	6	20x25x2	Tri-Pleat ES40LE 2302025240	\$2.55	
				Total Survey	\$158.70	